



**BUREAU
VERITAS**

Certificate of compliance

Applicant: Kaco new energy GmbH
Carl-Zeiss-Str. 1
74172 Neckarsulm
Germany

Product: Automatic disconnection device between a generator and the public low-voltage grid

Model: Powador 2002
Powador 3002
Powador 4202
Powador 5002
Powador 6002

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with DIN V VDE V 0126-1-1:2006-02 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with insulating function which the distribution network provider can access at any time.

Applied rules and standards:

DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02 and „Generator at the public low-voltage grid, 4th edition 2001, guideline for connection and parallel operation of generators in the public low-voltage grid” with VDN additions (2005) from the German Electricity Association (VDEW) and Association of network operator (VDN).

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report number: 08TH0280-VDE0126
Certificate number: U15-0086
Date of issue: 2015-03-18

Certification body

Dieter Zitzmann



Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to EN 45011 - ISO / IEC Guide 65