



**BUREAU  
VERITAS**

# Potvrda o usklađenosti

**Podnosilac:** KACO new energy GmbH  
Carl-Zeiss-Str. 1  
74172 Neckarsulm  
Nemačka

**Proizvod:** Automatski rasklopni uređaj između generatora i javne niskonaponske mreže

**Model:** Powador 60.0 TL3  
Powador 72.0 TL3  
*Pogledajte prilog za detaljan opis modela*

## Koristiti u skladu sa propisima:

Automatski rasklopni uređaj za nadzor trofaznog voda u skladu sa standardom DIN V VDE V 0126-1-1:2006-02, DIN V VDE V 0126-1-1/A1:2012-02, DIN VDE V 0126-1-1:2013-08 za fotonaponske sisteme sa trofaznom paralelnom vezom preko invertora u javnoj električnoj mreži. Ovaj automatski rasklopni uređaj predstavlja integralni deo pomenutog invertora. On služi kao zamena za elektroizolacioni rasklopni uređaj kome elektrodistributivna kompanija može pristupati u svako doba.

## Važeći pravilnici i standardi:

### DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02

Automatic disconnection device between a generator and the public low-voltage grid

### DIN V VDE V 0126-1-1/A1 (VDE V 0126-1-1/A1):2012-02

Automatic disconnection device between a generator and the public low-voltage grid; Amendment 1.

Koncept bezbednosti pomenutog proizvoda u trenutku izdavanja ove potvrde zadovoljava važeće bezbednosne specifikacije za navedenu upotrebu u skladu sa propisima.

**Br. izveštaja:** 12TH0351-VDE0126

**Br. potvrde:** U16-0333

**Datum izdavanja:** 2016-06-14

## Institut za sertifikovanje



Dieter Zitzmann

Certification body of Bureau Veritas Consumer Products Services Germany GmbH  
Accredited according to DIN EN ISO/IEC 17065



Deutsche  
Akkreditierungsstelle  
D-ZE-12024-01-00



## Annex to the certificate of compliance No. U16-0333

BUREAU  
VERITAS

### Additional models

Extract from test report: N/A

Report Nr.: 12TH0351

### Model / Type

**Powador 60.0 TL3 – M – INT**  
**Powador 60.0 TL3 – XL – INT**  
**Powador 60.0 TL3 – XL – INT – SPD 1+2**  
**Powador 60.0 TL3 – XL – F – INT**  
**Powador 60.0 TL3 – XL – F – SPD 1+2**

**Powador 72.0 TL3 – M – INT – Park**  
**Powador 72.0 TL3 – XL – INT – Park**  
**Powador 72.0 TL3 – XL – INT – SPD 1+2**  
**Powador 72.0 TL3 – XL – F – INT – Park**  
**Powador 72.0 TL3 – XL – F – SPD 1+2 – Park**