



**BUREAU
VERITAS**

Certificate of compliance

Applicant: KACO new energy GmbH
Carl-Zeiss-Str. 1
74172 Neckarsulm
Germany

Product: Photovoltaic inverter

Model: blueplanet 15.0 TL3 M2 WM OD IIG0
blueplanet 20.0 TL3 M2 WM OD IIG0

Use in accordance with regulations:

The inverters are tested according to electrical safety, grid protection, specified environmental influences and efficiency. For detailed information, please watch the corresponding test reports.

Applied rules and standards:

IEC 61727:2004	Characteristics of the utility interface
IEC 62116:2008	Islanding prevention measures for utility-interconnected photovoltaic inverters.
IEC 62109-1:2010	Safety of power converters for use in photovoltaic power systems
IEC 62109-2:2011	Safety of power converters for use in photovoltaic power systems
IEC 60068-2-1:2007	Environmental testing – Part 2-1: Tests – Test A: Cold
IEC 60068-2-2:2007	Environmental testing – Part 2-2: Tests – Test B: Dry heat
IEC 60068-2-14:2009	Environmental testing – Part 2-14: Tests – Test N: Change of temperature
IEC 60068-2-30:2005	Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12h + 12 h cycle)
IEC 60068-2-75:1997	Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests (IEC 62262:2002 – IK code)
IEC 60529	Degree of protection provided by enclosure (IP Code: 65) Protection against IP6X according to EN 60529, sub-cl. 13.4 and 13.6 Protection against IPX5 according to EN 60529, sub-cl. 14.2.5

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 10TH0306-EN50438_1; 10TH0306-IEC60068_1
10TH0306-IEC61727_1; 10TH0306-IEC60529_0

Certificate number: U17-0364

Date of issue: 2017-07-27

Certification body



Holger Schaffer

Certification body of Bureau Veritas Consumer Products Services Germany GmbH
Accredited according to DIN EN ISO/IEC 17065