

Certificate

Applicant: Kaco new energy GmbH
Carl-Zeiss-Str. 1
D-74172 Neckarsulm
Germany

Product: Photovoltaic Inverter with integrated automatic disconnection device between a generator and the public low-voltage grid

Modell:	blueplanet							
	2.0TL 1M1	2.6TL 1M1	3.0TL 1M1	3.0TL 1M2	3.5TL 1M2	3.7TL 1M2	4.0TL 1M2	4.6TL 1M2
Rating: [kVA]:	2,00	2,60	3,00	3,00	3,45	3,68	4,00	4,60

Intended use:

An automatic disconnection device with single-phase mains surveillance in accordance with Engineering Recommendation G83/2 for photovoltaic systems with a single-phase parallel coupling via an inverter to the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

**Engineering Recommendation G83/2
Issue 2 – August 2012**

Recommendations for the connection of small-scale embedded generators in parallel with public low-voltage distribution networks.

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 14PP047-03

Certificate No: 14-131-00

Date of issue: 2014-10-20



Andreas Aufmuth
Certification Department

