

Certificate

Applicant: **Kaco new energy GmbH**
Carl-Zeiss-Str. 1
D-74172 Neckarsulm
Germany

Product: **Photovoltaic Inverter**

Model:	blueplanet								
	2.0TL 1M1	2.6TL 1M1	3.0TL 1M1	3.0TL 1M2	3.5TL 1M2	3.7TL 1M2	4.0TL 1M2	4.6TL1 M2	5.0TL1 M2

Intended use:

Automatic disconnection device with single-phase mains surveillance in accordance with NRS 097-2-1 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

NRS- 097-2-1:2010, Edition 1
Grid interconnection of embedded generation
Part 2: Small-scale embedded generation
Section 1: Utility interface

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 14PP047-17

Certificate No: 15-202-00

Date of issue: 2015-10-19



Andreas Aufmuth
Certification Department

