



APPROVALS®

## Certificate of Suitability

**Certificate No.:** SAA151225

**Certificate Holder:** KACO new energy GmbH  
Carl-Zeiss-Str. 1,  
74172 Neckarsulm,  
Germany

**Class Description:** Non-Declared  
**Product Description:** PV Inverter  
**Brand Name:** KACO new energy  
**Model No.:** blueplanet 5.0 TL3 M2 WM OD IIG0  
**Markings:** Input: MPP voltage range 240-480Vdc  
Max 1000Vdc 2x11A  
Output: 400/230V~ 3/N/PE 45-65Hz  
3x7.62A 5000VA

**Standard:** AS 4777.2:2005  
AS 4777.3:2005  
IEC 62109-1 Ed. 1.0  
IEC 62109-2 Ed. 1.0

**Conditions:** Nil

**Certification Mark:** SAA151225 or RCM

**Date First Registered:** 21 August 2015

**Date of Expiry:** 21 August 2020


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 21-08-15 151225/1



APPROVALS®

## Certificate of Suitability

**\*Addendum\***

**Certificate No.:** SAA151225

**Date of Issue:** 21 August 2015

**Class Description:** Non-Declared  
**Product Description:** PV Inverter

<b>Additional Models</b>	<b>Description</b>
blueplanet 6.5 TL3 M2 WM OD IIG0	Input: MPP voltage range 310-800Vdc Max 1000Vdc 2x11A Output: 400/230V~ 3/N/PE 45-65Hz 3x9.98A 6500VA
blueplanet 7.5 TL3 M2 WM OD IIG0	Input: MPP voltage range 350-800Vdc Max 1000Vdc 2x11A Output: 400/230V~ 3/N/PE 45-65Hz 3x11.45A 7500VA
blueplanet 9.0 TL3 M2 WM OD IIG0	Input: MPP voltage range 420-800Vdc Max 1000Vdc 2x11A Output: 400/230V~ 3/N/PE 45-65Hz 3x13.76A 9000VA


For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 21-08-15 151225/2